

PFAS6 Results for Hingham Street WTP, Finish Water

| Quarterly Compliance Period | Monitoring Period | Sample Collection Date | PFAS6 Result (ng/L) | Quarterly Average (ng/L) | PFAS6 MCL (ng/L) |
|-----------------------------|-------------------|------------------------|---|--------------------------|------------------|
| Quarter 1, 2021 | Month 1 | 1/26/2021 | 20.95 | 23* ** | 20 |
| | Month 2 | 2/17/2021 | 25.87 | | |
| | Month 3 | 3/31/2021 | 21.81 | | |
| Quarter 2, 2021 | Month 1 | 4/26/2021 | 20.39 | 20** | 20 |
| | Month 2 | 5/31/2021 | 18.54 | | |
| | Month 3 | 6/24/2021 | 21.82 | | |
| Quarter 3, 2021 | Month 1 | 7/30/2021 | 21.47 | 24* ** | 20 |
| | Month 2 | 8/31/2021 | 21.86 | | |
| | Month 3 | 9/29/2021 | 29.52 | | |
| Quarter 4, 2021 | Month 1 | 10/29/2021 | 17.6 | 20** | 20 |
| | Month 2 | 11/23/2021 | 23.1 | | |
| | Month 3 | 12/29/2021 | ***N/A - results did not meet quality control standards | | |
| Quarter 1, 2022 | Month 1 | 1/27/2022 | 21.6 | 20** | 20 |
| | Month 2 | 2/28/2022 | 19.2 | | |
| | Month 3 | 3/31/2022 | 20.28 | | |

*If any sample results cause the **quarterly average** to exceed the MCL, the PFAS6 MCL has been violated

**Based on the Massachusetts DEP significant factors rule for interpreting PFAS6 data

***Results must meet a strict QA/QC standard, and invalid results cannot be used when determining compliance