

Debra Shettlesworth

Subject: FW: 104 West Water Street

From: Thomas Heaney <theaney@rockland-ma.gov>
Sent: Thursday, June 15, 2023 8:45 AM
To: Delshaune Flipp <healthagent@rockland-ma.gov>
Subject: RE: 104 West Water Street

Good Morning,

I would like to see if the apartment has Smoke/Co detectors. It should only require 1 Smoke Detector in the bedroom and one combination Smoke and Co outside of bedroom. They will need to be hardwired interconnected.

Tom